



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146AU0399

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	LOXEAL s.r.l. Via Marconato, 2, I-20031 Cesano Maderno (MI)
Distributor <i>Vertreiber</i>	LOXEAL s.r.l. Via Marconato, 2, I-20031 Cesano Maderno (MI)
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product Description <i>Produktbezeichnung</i>	sealing material for metallic screwed joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2018
Model <i>Modell</i>	LOXEAL® 55-03
Test Reports <i>Prüfberichte</i>	type testing: 14/339/5146/1 from 08.04.2015 (EBI) laboratory control test: 19/144/5146/08 from 19.06.2019 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 31.10.2024 / 19-0331-GNV
Ablaufdatum / Aktenzeichen

24.07.2019 Fi A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
LOXEAL® 55-03	class: H	for diameters > DN 10 up to DN 50

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

suitable for: metal thread connections for application by coarse threads
not allowed: in gas installations according to DVGW-TRGI 2018

DVGW